CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING – BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

CATEGORY: Control Unit (Non High-Rise)

LISTEE: ADT Security Services, Inc., 695 Route 46 West, Suite 200, Fairfield, NJ 07004-1561
Contact: Ron Dalton (310) *619-2342 FAX (310) *619-2208

DESIGN: Model ADT-3000 fire alarm control unit. Power limited. Automatic, manual, coded, noncoded, local, auxiliary, remote station, (DACT), (reverse polarity), proprietary, (multiplex), central station, waterflow and sprinkler supervisory service. Unit is also suitable for smoke control. Refer to listee's data sheet for additional detailed product description and operational considerations. System components:

3-BPS/M, 3-BPS/M/230	Booster Power Supply
3-PPS/M, 3-PPS/M-230	Primary Power Supply
3-BBC/M, 3-BBC/M-230	Battery Booster Charger Power Supply
3-RS232	CPU RS232 Comm
3-XMEM	CPU Memory Option
3-IDC8/4	Zone Card
3-CPU, 3-CPU, 3-CPU2, *3-CPU3	Central Processing Unit
3-LCD, *3-LCDXL	CPU LCD Display
3-OPS	Off Premises Signaling Module
3-LDSM	LED Display Module
3-LRMF	Blank LRM Filler
3-CHAS4, -CHAS-5, -CHAS-7	Module Chassis
ADT-CAB-5(R),-7(R),-14(R),-21(R)	Module Cabinet (red)
3-TAMP, 3-TAMP5	Tamper Switch
ADT-RCC7(R),-RCC14(R),-RCC21(R)	Closet Cabinet (red)
3-PSMON	Power Supply Drive Monitor
3-BPMON	Power Supply Booster Monitor
3-24G,-24R,-24Y,-12RY,-12SY,-12SR,-12SG	LED Display
3-12/RY,-12/2Y,-12/2S2Y,-12/S1GY	LED Display
3-12/S1RY,-18S1G2Y,-6/3S1G2Y	LED Display
3-6/3S1GYR,-18S1GYR, -6/3S3L	LED Display
ADT-CAB5BR	Enclosure
3-SSDC, *3-SSDC1, *3-SDDC1	Single Loop Controller Module
3-SDC, *3-SDC1	Signature Data Card
3-ASU, *3-DSDC1	Audio Source Module
3-FTCU	Firefighter Phone Module
3-ASU/FT	Audio/Firefighter Module
3-ZA30, 3-ZA15	Amplifier
3-RS485(130316/130410-01)	Network Communication Card
3-RS485A, 3-RS485B, 3-RS485R	Network Communication Card
3-DSDC	Dual Loop Controller Module
3-FIB, 3-FIBA	Fiber/Copper Data Com Module
*3-FIBMB	Fiber Optic Interface Card

CDR-3	Coded Output Module
3-AADC, *3-AADC1	Analog Addressable Communication Module
3-ATPINT	ATPC Interface Module
3-REMICA, 3-REMICP	Remote Microphone
PT1-S	System Printer
PT1-P	System Printer Parallel
3-ZA90, 3-ZA20A, 3-ZA20B	Zone Amplifiers
3-ZA-40A, 3-ZA40B, *ZA95	Zone Amplifiers
ADT-ATCK	Attack Kit Cover for 3-RCC7R cabinet
3-MODCOM, 3-MODCOMP	Modem communicator/pager interface
3-NSHM1, 3-NSHM2	Modem Communication Cards
3-SAC	Security Access Control Module

RATING: 120 VAC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as fire alarm control unit for use with separately listed electrically and functionally compatible initiating and indicating devices. Units can generate the distinctive temporal code pattern fire alarm signal as required per NFPA 72, 2002 Edition.

This control unit meets the requirements of UL-864, 8th Edition Standard.

NOTE: For **Fire Alarm Verification Feature**, the maximum Retard/Reset/Restart period shall not exceed 30 seconds.

XLF: 7165-1591:186

*Rev. 07-07-2005

This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 13, 2008**   *Listing Expires **June 30, 2009***

Authorized By: **BEN HO**, Chief
Fire Engineering Division